




DIGITAL OUTPUTS



261)DOP1 RECTIFY EN: **ENABLED**
262)DOP1 THRESHOLD: **0.00**
263)DOP1 INVERT MODE: **NON-INVERT**
682)DOP1 O/P BIN VAL: **LOW**
DOP1 GETFROM: **296)DIGITAL POST 1**



264)DOP2 RECTIFY EN: **ENABLED**
265)DOP2 THRESHOLD: **0.00**
266)DOP2 INVERT MODE: **INVERT**
683)DOP2 O/P BIN VAL: **LOW**
DOP2 GETFROM: **120)AT ZERO SPD FLAG**



267)DOP3 RECTIFY EN: **ENABLED**
268)DOP3 THRESHOLD: **0.00**
269)DOP3 INVERT MODE: **NON-INVERT**
684)DOP3 O/P BIN VAL: **HIGH**
DOP3 GETFROM: **698)HEALTHY FLAG**