



Leave at least 700 mm around generator for easier maintenance of generator + defined for rotor and cooler extraction

around 1450 mm for cooler extraction

D	5.5249	New main box inlet, removed PMG conn. box, added *	25/10/2018	Kijačić	
C	5.5224	Exchanger 388 to 385, COMSEAL 18/10 to 16/16	10/10/2018	Kijačić	
B	5.5217	DE Ø120x210, DN80 to DN65	05/10/2018	Kijačić	
A		Added brush on DE side sense of rotation		Burek	
Izdavanje Issue		Proizmena broj Change number	Datum Date		
Mjerilo Scale		Opis promjene Change description	Ime Name		
A3			Bc. No.:		
INGETEAM		Masa Mass	Sirovina Raw material		
		5100 kg			
Tolerancije slobodnih mjera Free tolerances		Kvaliteta površine Surface quality	Naziv Title		
			Mjerna skica generatora		
9/2018.		Ime Name	Generator outline drawing		
Konstruirao Burek		Potpis Signature			
Dizajnirao HIŽAR					
Ispitao HIŽAR					
Standard Standard					
Odobrio TIŠIJAR					
Izvorni crtež Original drawing					
18-1-0118-P4-3d					
KONČAR		Broj No.:			
KONČAR - Generatori i motori d.d.		M41210			
		List Sheet: 1			
		Listova Sheets: 1			